## ADDENDUM SET 1

13th September 2023.

To all Prospective bidders,

REF: TENDER NO. KRA/HQS/NCB-005/2023-2024 – PROVISION OF GENERATOR MAINTENANCE SERVICES FOR USHURU PENSION TOWERS AND USHURU PENSION PLAZA FOR A PERIOD OF THREE (3) YEARS

Kenya Revenue Authority wishes to inform prospective bidders of the following clarifications/ amendment to the Tender document:

| No.   | Clarification   | KRA Response  |
|---|---|---|
| No. 1.  | Clarification  We kindly seek for clarification with reference to technical evaluation on page 31 of the bid document as follows;  A. Under the service description, the service provider is required to:  1. Place a supervisor/generator technician at Ushuru Pensions Tower and Ushuru Plaza from 8;00hrs to 17:00hrs Monday through Friday.  2. Ensure generator house concrete floor must be degreased and washed every day.  3. Securely power spray radiators with water to remove dust once every week.  4. Daily check coolant level in radiator.  5. Daily check battery acid level and battery terminal connections. | Prospective bidders are advised that these items listed from (1-5) should be included in the labour item that appears in the price schedule for each quarter  |
| 2.  | The above service description has a cost implication which is external to the routine quarterly service.  Kindly clarify on how to price the above mentioned service as it is not included in the price schedule.  Kindly requesting if we can attend a site visit/ assessment for the tender Provision of Generator Maintenance Services for Ushuru Pension Towers and Ushuru Pension Plaza for A Period of Three (3) Years  | Prospective bidders are advised that they can visit the site any time before Friday, 15th September 2023, 4.00pm but with prior notification to the Authority when they intend to visit the site for internal arrangements. |
| Bidders are advised to acknowledge receipt of this addendum uploaded and published on our website on 13 <sup>th</sup> September 2023. |   |   |



ISO 9001:2015 CERTIFIED

The Addendum form part of the bidding document and is binding to all bidders. All other terms and conditions of the tender remain the same. You are therefore required to immediately acknowledge the receipt of this addendum.

Regards,

Bernard Mukundi

For: Ag. Deputy Commissioner – Supply Chain Management