



KENYA REVENUE AUTHORITY

ISO 9001:2015 CERTIFIED

11th June, 2019

TENDER NO. KRA/HQS/NCB-072/2018-2019 - SUPPLY, DELIVERY, INSTALLATION AND TESTING OF 100 KVA MODULAR UPS

ADDENDUM SET "1"

All prospective bidders are advised to acknowledge the clarification/ addendum for the above tender through procurement@kra.go.ke

Minimum Technical Specifications for supply, delivery and installation of 100 KVA Modular UPS for KRA Marketing Department 3rd Floor Time Tower_(based on capacity of 300 PCs)			
1. Clarification on Item "42" of the Technical Specifications Requirements			
No.	Feature	Minimum Specifications	Bidder's Response
42.	Electrical accessories connections	<p>LOT. (Input and Output supply cables, 3 phase tap off unit ,battery cables, battery cabinet, switch gear boards/cabinets, screws, wall plugs, cable ties etc. for installation, provision of labour, testing and commissioning the installation. Cable sizing to be based on full capacity).</p> <p>The bidder MUST supply and install all the electrical accessories and components (listed above) needed to ensure the UPS is fully integrated, functional, and supplying power to the installed socket outlets. Exact requirements to be determined during site survey.</p>	
2. Additional Item "44" of the Technical Specifications Requirements			
44.	Post warranty support and maintenance	<p>The bidders to separately provide two (2) year framework unit costs for UPS modules, batteries, parts, accessories and labour costs after the end of warranty. These costs SHOULD be excluded in the form of tender sum but provided separately as post warranty maintenance option for KRA</p>	

The Clarification/Addendum form part of the bidding document and is binding to the bidder. All other terms and conditions of the tender remain the same. You are therefore required to immediately acknowledge the receipt of this addendum.

Regards,


Benson Kiruja
For: Deputy Commissioner - Supply Chain Management



Tulipe Ushuru Tujitegeme!

