



KENYA REVENUE AUTHORITY

ISO 9001:2015 CERTIFIED

19th October, 2020

To all Prospective bidders,

TENDER NO. KRA/HQS/NCB-012/2020-2021 - PROVISION OF GENERAL ELECTRICAL SYSTEMS, FIRE DETECTION SYSTEMS AND COMMUNICATION NETWORK INSTALLATION AT USHURU PENSION TOWER BUILDING.

RE: ADDENDUM /CLARIFICATION SET “2”

Kenya Revenue Authority wishes to inform prospective bidders of the clarifications highlighted below:

Table 1: Addendum/Clarification to Bidder’s Query

No.	Addendum	
1.	Page 226, Item 1.8: The workstation and printer have been omitted, (to be separated from the server). The card printer has been included as a separate item as item 1.9. Refer to Appendix 1	
2.	Page 230, Item 1.4: Quantity has been increased to 2 No. to take care of the workstation above. Refer to Appendix 1	
No	Clarification	KRA Response
3.	We would like to Know the Make and Model of the Current Access Control System at Times Tower as it is a requirement that the proposed system MUST be integrated with the existing system in Times Tower.	Security system at Times Tower: - Apollo Access Control System (APACS)
EXTENSION OF TENDER OPENING		
4.	PREVIOUS TENDER CLOSING DATE	NEW TENDER CLOSING DATE
	22nd October 2020 at 11.00 a.m.	29th October 2020 at 11.00 a.m.
Note: Prospective bidders are hereby advised to align their Tender Security to the new tender opening date i.e to be valid up to 28th October, 2021		

The addendum/clarifications form part of the bidding document and is binding to the bidder. All other terms and conditions of the tender remain the same. You are therefore required to immediately acknowledge the receipt of this addendum/clarifications.

Regards,

Benson Kiruja

For: Deputy Commissioner - Supply Chain Management

BM




Tulipe Ushuru Tujitegemee !

KENYA
VISION 2030

APPENDIX 1

BILL ITEM No.	ITEM DESCRIPTIONS	QTY.	UNIT	UNIT RATES	TOTAL AMOUNT- KSHS.
	Brought Forward from Previous page				
1.7	IP Based Master Controller with support for up to 1,240,000 card holders or 65,000 events and up to 96 device control	Item	1		
1.8	Design & supply unified server for Access Control and CCTV complete with client server operating on Windows ® software managing all access control doors on a single platform server to manage local and remote users with at least 100 access group levels, event monitoring and time schedule management with visitor management, Time and Attendance Software for up to 100,000 users. The access control manager to have video management system with video analytics capability. The access control system will be integrated/configured for redundancy for the existing system. The current platform is Genetec 5.5 Professional - to be upgraded to 5.8 Enterprise edition and the master controller is Synergis cloud link.	Item	2		
1.9	Card printer with dual sided printing module and as per the particular specifications.	Item	1		
1.10	Access control Biometric enrollment kit	Item	1		
1.11	Lifecam Hd Web Camera with a built-in microphone and USB 2.0 interface	Item	1		
1.12	Allow for interconnection to Fire Alarm Detection System	Item	1		
LEVEL 03 CARRIED FORWARD TO COLLECTION PAGE					



APPENDIX 1

ITEM	DESCRIPTION	UNIT	QTY	RATE	TENDER AMOUNT
				KSHS	Kshs.
BILL No. 2	CCTV, LEVEL 03 <i>Supply, deliver to site, install, commission and test the following:</i>				
1.1	6 mp indoor PoE Ceiling/wall mounted dome CCTV camera with the following features; <ul style="list-style-type: none"> • Max 5M (2560x1960), Full HD(1080p) resolution • 25fps @ 2560x1960 • Min.Illumination 0Lux (IR Distance 30m) • Enhanced WDR (120dB) • 2.8 ~ 8.5mm (2.8x) motorized varifocal lens • Tampering Alarm • Lightcatcher capability • PoE supports. • Resolution:5MP (3K) • Camera Style:Dome • Camera to be complete with 32GB micro SDHC 	No.	11		
1.2	Network Attached Storage (NAS) box Complete with SATA HDDs capable of providing 90 Days for continuous recording for all cameras with supporting calculation from the Manufacturer, 3 year warranty.	No.	1		
1.3	49" LED Monitor for CCTV use. Screen to have the following features; Supports 1920 x 1080p resolution, 16:9 display, 5ms response, High contrast ratio of 1000:1,	No.	2		
1.4	Client workstation with Intel i7 10 th generation or Xeon E5 series, Nvidia quadro M2000 Graphics card with 4 display ports with 4no. Display ports to HDMI adapter, 16GB RAM, 1TB SATA Hard Disk. PC to be complete with windows 10 Pro 64 bit operating system.	No.	2		
1.5	Allow for Cabling between cameras, POE switches and Monitors	Item	1		
Total Amount C/F to Collection Page					

