

ISO 9001:2015 CERTIFIED

1st November 2019

To all prospective bidders,

RE: CLARIFICATION SET "1"

TENDER NO. KRA/HQS/NCB/024/2019-2020- SUPPLY AND DELIVERY OF LED LIGHTING AT TIMES TOWER (RESERVED FOR AGPO)

Kenya Revenue Authority wishes to inform prospective bidders of the clarification highlighted below

Bidders clarifications questions	KRA's Response
In the price schedule attached, we are required to supply 1450 pcs of the 600mm2 X600mm2 LED PANEL. (Recess) and 5800 pcs of the 600mm2 X600mm2 Acoustic Panels. However, the difference in the two items were not explained to us in the pre-bid meeting and also the technical specifications do not specify any difference	 The 600mm X 600mm (Recessed) LED PANEL will replace the current (existing) 600mm X600mm (Recessed) Fluorescent li ght fittings. While the 600mm X 600mm Acoustic ceiling Panels will 'fill' the 'gaps' left by removing the current (existing) 600mm X 600mm (Recessed) Fluorescent light fittings.

Prospective bidders are advised that the clarification of the above tender has been published via KRA E-Procurement Portal and KRA Website www.kra.go.ke

The Clarification form part of the bidding document and is binding to the bidder. All other terms and conditions of the tender remain the same. You are therefore required to immediately acknowledge the receipt of this addendum through eprocurement@kra.go.ke

Regards,

For: Deputy Commissioner - Supply Chain Management



